

CITY OF LOS ANGELES  
CALIFORNIA

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

VAN AMBATIELOS  
PRESIDENT

JAVIER NUNEZ  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
ELVIN W. MOON



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
BUILDING AND SAFETY  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

OSAMA YOUNAN, P.E.  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

JOHN WEIGHT  
EXECUTIVE OFFICER

Nikhil Koganti  
Performance Pipe  
5085 W. Park Blvd. #500  
Plano, TX 75093

Telephone: 972-599-7309

Models:

Driscoplex 6500 (yellow or black); Sizes (in.): 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 4, 6

File Number: M-110109

Effective Date: 05/01/2020

Expiration Date: 05/01/2021

Manufacturer: PERFORMANCE PIPE

Item: POLYETHYLENE GAS PIPE

**PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES**

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

**CONDITIONS OF APPROVAL:**

**See attached list of Conditions of Approval.**

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

Irene M Pool Tamayo  
Mechanical Testing Laboratory, Test Engineer

**Performance Pipe  
Polyethylene Gas Pipe**

**M-110109**

**Conditions of Approval**

1. The pipe shall be installed outdoors, underground only as plastic yard piping in natural gas service systems; except as permitted by Section 1210.1.7 of the Los Angeles Plumbing Code (LAPC), 2020 Edition.
2. The pipe shall not be exposed to sunlight.
3. Plastic yard piping shall be permanently identified by attaching a metal tag to the meter end of the piping system stating, "Plastic Yard Piping."
4. The pipe shall not be installed where the maximum operating pressures exceed 5 psi, or the ambient temperature is above 100 degrees F or is below -20 degrees F.
5. Installation of the products shall be in accordance with the manufacturer's printed installation instructions and the LAPC, 2020 Edition.
6. These pipes may be cold-bent to a radius of curvature of 20 (twenty) times the nominal pipe size without using any fittings.
7. Only approved polyethylene fittings may be used with these products.
8. Approved transition fittings shall be used between polyethylene piping and piping approved for above grade application.
9. Plastic pipe and fittings shall not be threaded, sealed with cement or adhesives.
10. The products shall not be routed through buildings or embedded in concrete.
11. Polyethylene piping shall have at least 12 inches of earth cover. Where external damage to the pipe from external forces is likely to result, the cover shall not be less than 18 inches, or other equivalent protection.
12. No gas piping system or part thereof, shall be covered, concealed or put into use until it has been tested, inspected and accepted.
13. Pipe shall be sized in accordance with Chapter 12 of the LAPC, 2020 Edition.

14. The pipe shall be permanently marked at regular intervals not to exceed 2 (two) feet as follows:

- a. Pipe size including sizing system (IPS, CTS, or OD)
- b. SDR or minimum wall thickness
- c. Manufacturer's name and/or Trademark
- d. "GAS"
- e. Pipe material designation code
- f. Elevated temperature (as applicable)
- g. "ASTM D 2513"
- h. Manufacturer's lot code
- i. Additional information, including date of manufacture, coil number sequential footage, third party certification mark etc.
- j. Melt index category

\*\*\*\*\*