



*Safe Handling and Storage of  
Isomerized 1-Hexadecene  
and  
Isomerized 1-Octadecene*


THIS PAGE INTENTIONALLY LEFT BLANK

August 1, 2017

## ***Operational Excellence Policy***

We will strive each day to conduct our business in a safe, secure, injury-free, and environmentally responsible manner. We are committed to comply with all laws and regulations applicable to our facilities and business activities and to comply with all voluntary programs to which we elect to subscribe. We will strive to make optimal use of the resources we consume and minimize emissions and waste. We will strive to limit the risks of our products throughout their lifecycle. We are committed to reducing risks in our operations to safeguard our employees, contractors, and the communities where we operate and engage in business activities. We will openly communicate our results and welcome the input of our employees and contractors, regulatory agencies, our communities, our customers, and other interested stakeholders.

We will accomplish this by integrating safety, security, health, environmental, reliability, and quality into our management processes using our Operational Excellence System (OE). OE will be used worldwide to: set goals for improvement; provide alignment of activities and resources; assess and manage risks; gain stakeholder input; and, rigorously audit our performance against operational objectives and compliance requirements.



Mark E. Lashier  
President & CEO

Chevron Phillips Chemical Company LLC

# TABLE OF CONTENTS

<b>PRODUCT STEWARDSHIP</b>	.....2
<b>INTRODUCTION</b>	.....3
<b>PART 1 SPECIFICATIONS, PROPERTIES AND TEST METHODS</b>	
Isomerized Alpha Olefin 16 Specifications.....	4
Isomerized Alpha Olefin 18 Specifications.....	4
Properties.....	4
Recommended Test Methods.....	6
<b>PART 2 SAMPLING AND HANDLING</b>	
Training.....	7
Recommended Practice for Sampling.....	7
Static Electricity and Grounding.....	8
Product Loading/Unloading Requirements.....	8
Safety References.....	10
<b>PART 3 STORAGE DESIGN RECOMMENDATIONS</b>	
Storage Tanks.....	11
API and ANSI Design References.....	11
Particulate Matter.....	12
Filters.....	12
Hoses.....	12
Pumps.....	12
Valves.....	13
Pipelines.....	13
<b>PART 4 HEALTH, ENVIRONMENT, FIRE AND ACCIDENTAL RELEASE INFORMATION</b>	
Safety Data Sheet Information.....	14
<b>PART 5 TRANSPORTATION INFORMATION AND REGULATORY PROFILE</b>	
Safety Data Sheet Information.....	14
<b>PART 6 APPENDIX</b>	
Glossary of Terms, Abbreviations and Organizations.....	15

## PRODUCT STEWARDSHIP

Chevron Phillips Chemical Company LP ("Chevron Phillips Chemical Company") is committed to being a good Product Steward of the products we produce. We want anyone who comes in contact with one of our products to have access to information that will help them to understand its potential risk and how to use it safely. The thrust of our Product Stewardship program is the implementation of an Operation Excellence Management System (OEMS) initiative, which makes health, safety and environmental protection an integral part of our products. Successful implementation of this system must include a shared responsibility of all those who come in contact with a product throughout its life cycle. Chevron Phillips Chemical Company will continue to work with customers and others to help ensure that all who use and handle our products follow safe and environmentally sound practices.

**The information contained in this technical bulletin is not intended to, nor does it, amend or replace the Chevron Phillips Chemical Company Safety Data Sheet (SDS) for Isomerized Alpha Olefin 16 (#7890) and Isomerized Alpha Olefin 18 (#7891). The most current SDS can be obtained from Chevron Phillips Chemical Company at [www.cpchem.com](http://www.cpchem.com) or by calling (800) 852-5530 and should be carefully examined prior to working with these products.**



## INTRODUCTION

Chevron Phillips Chemical Company Isomerized Alpha Olefin 16 (IAO 16) and Isomerized Alpha Olefin 18 (IAO 18) have a variety of end uses, but their two primary uses are as drilling mud base fluids and as feedstock for paper sizing agents. When used as a drilling mud base, these products make up about 50% of the drilling mud by volume and perform three basic functions in drilling muds. First, IAO 16 and IAO 18 act as a lubricant for the drilling shaft and bit. Second, these products act as a sealant for the drilling string. Finally, the materials act as a vehicle for removing debris and cuttings from the drilling hole.

When used to make paper sizings, IAO 16 and IAO 18 react with maleic anhydride to produce the desired liquid alkenyl succinic anhydride (ASA).

Chevron Phillips Chemical Company IAO 16 and IAO 18 are made via a patented two part process. First, the 1-hexadecene and 1-octadecene alpha olefin feedstocks are manufactured by Chevron Phillips Chemical Company at its Cedar Bayou, Texas petrochemical complex. The feedstocks are then passed through a fixed bed catalyst reactor to produce the isomerized product. This isomerization process randomizes the double bond along the carbon chain and results in a small amount of branching in the final product. Manufacturing is conducted in closed systems. Typical IAO 16: IAO 18 ratios in blends include 50:50 and 65:35. These blends may be supplemented by other carbon number olefins to enhance performance and supply.

**NOTE:**

**THIS BROCHURE DOES NOT AMEND OR REPLACE OFFICIAL PUBLICATIONS, SAFETY REGULATIONS NOW IN USE, SAFETY DATA SHEETS OR COMMERCIAL TERMS OF SALE. CHEVRON PHILLIPS CHEMICAL COMPANY MAKES NO GUARANTEE OF THE ACCURACY OF THE CONTENTS OF THIS BROCHURE OR ANY WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, WITH RESPECT TO THE USE OF THIS INFORMATION OR ITS APPLICABILITY. THE USER ASSUMES ALL RISK AND LIABILITY ASSOCIATED WITH THE INFORMATION IN THIS BROCHURE.**

## PART 1

### SPECIFICATIONS, PROPERTIES AND TEST METHODS

#### ISOMERIZED 1-HEXADECENE AND ISOMERIZED 1-OCTADECENE SPECIFICATIONS

Please reference the Chevron Phillips website for sales specifications at [www.cpchem.com](http://www.cpchem.com)

#### PROPERTIES

PROPERTY	METHOD	Isomerized Alpha Olefin 16	Isomerized Alpha Olefin 18
Autoignition, °C (°F)	1	215 (419)	240 (464)
Average Molecular Weight		224	252
Boiling Point, °C			
<u>Vapor Pressure, torr</u>			
760		280	310
500		260	290
100		205	230
50		185	210
20		160	185
Color		Colorless to pale yellow	Colorless to pale yellow
Density of the Liquid, gm/cm <sup>3</sup>			
<u>Temperature, °C</u>			
15.6	ASTM D 1298	0.78	0.79
40		0.77	0.77
Freezing Point, °C (°F)	ASTM D 1015	<-10°C (14°F)	0°C (<32°F)
Molecular Formula		C <sub>16</sub> H <sub>32</sub>	C <sub>18</sub> H <sub>36</sub>
Odor		Olefinic	Olefinic
Refractive Index (N <sub>D</sub> ), 25°C	ASTM D 1218	1.4	1.4
Relative Density (Specific Gravity) <sup>2</sup>			



PROPERTY	METHOD	Isomerized Alpha Olefin 16	Isomerized Alpha Olefin 18
<u>Temperature, °C</u>			
15.6		0.78	0.79
25		0.78	0.79
Viscosity			
<u>Temperature, °C</u>	ASTM D 445	Absolute Viscosity, <u>centiPoise</u>	Absolute Viscosity, <u>centiPoise</u>
40		2.0	2.8
<u>Temperature, °C</u>	ASTM D 445	Kinematic Viscosity, <u>centiStokes</u>	Kinematic Viscosity, <u>centiStokes</u>
40		2.9	3.75
100		1.1	1.4

**REFERENCES AND NOTES:**

<sup>1</sup>Values are calculated based on the known values of Chevron Phillips Chemical Company's regular NAO product line.

<sup>2</sup>Values are calculated from the density of the liquid (obtained experimentally) and the density of pure water at 15.6 °C (0.999012 g/cm<sup>3</sup>).

## **RECOMMENDED TEST METHODS**

The following ASTM methods<sup>(1)</sup> are recommended for the analysis of IAO 16 and IAO 18:

1. D 92 Test Method for Flash and Fire Points by Cleveland Open Cup, Vol. 05.01
2. D 97 Test Method for Pour Point of Petroleum Products, Vol.05.01
3. D156 Test Method for Saybolt Color of Petroleum Products (Saybolt Chromometer Method), Vol. 05.01
4. D 287 Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method), Vol. 05.01
5. D 445 Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (and the Calculation of Dynamic Viscosity), Vol. 05.01
6. D 611 Test Methods for Aniline Point and Mixed Anile Point of Petroleum Products and Hydrocarbon Solvents, Vol. 05.01
7. D 1015 Test Method for Freezing Points of High-Purity Hydrocarbons, Vol. 05.01
8. D 1218 Test Methold for Refractive Index and Refractive Dispersion of Hydrocarbon Liquids, Vol. 05.01
9. D 1298 Practice for Density, Relative Density (Specific Gravity), or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method, Vol. 05.01
10. D 4176 Test Method for Free Water and Particulate Contamination in Distillate Fuels (Visual Inspection Procedures), Vol.05.02

Notes:

<sup>(1)</sup>1996 Annual Book of ASTM Standards

## PART 2

### SAMPLING AND HANDLING

#### TRAINING

In any workplace, training should be conducted before sampling and handling operations of IAO 16 and IAO 18 are undertaken. Several commercial websites provide access to Code of Federal Regulations, NIOSH, and OSHA databases which may help in answering questions and setting up safety programs. The training program may include the following:

1. Properties and health hazards of IAO 16 and/or IAO 18.
2. Safe work and good housekeeping practices.
3. The importance of protection from IAO 16 and/or IAO 18 contact; the proper clothing and cleaning requirements to ensure worker protection.
4. Signs and symptoms of IAO 16 and/or IAO 18 exposure and action to be taken.
5. The care that must be taken whenever and wherever IAO 16 and/or IAO 18 are used, handled, stored, and transported.
6. Emergency procedures for leaks, spills, and fires, including protective clothing to be worn in such instances. Check the product's MSDSs for further information.
7. First aid measures to be used after exposure.
8. The availability of written IAO 16 and/or IAO 18 usage, health hazard, and training program procedures.

It is recommended that this generalized sampling and handling training program should be part of a worker's initial instruction. Refresher training should be scheduled at least annually thereafter. A summary of accidental release, fire, and health information is presented in Section 4 of this brochure.

#### RECOMMENDED PRACTICE FOR SAMPLING

This information is provided for use in establishing sampling and handling procedures. This information should only be utilized in conjunction with an existing health and safety program and cannot be used as a substitute for expert safety and medical advice.

#### **SAMPLING:**

Samples may be taken through the sampling port (tank) or the manway opening (vessel) by means of a clean, dry 1-qt. (1-L) bottle held in a clean, dry sheath of nickel or stainless steel attached to a long rod or lightweight chain of the same material. Fit the bottle with a glass stopper to which is attached a light metal chain. Lower the bottle to near the bottom of the tank and pull out the stopper with a sharp jerk of the chain. Raise it at such a rate that it is about three fourths full when it emerges from the liquid. Stopper the bottle before attempting to rinse the material from the outside. Label the sample bottle according to OSHA Regulations (refer to 29 CFR 1910.1200).

**Note – No special respiratory protection is normally required. Other personal protective gear may be required depending on exposure limits set in the individual workplace.**

Emphasis should be placed on cleanliness and dryness. Both the sample bottle and its holder must be CLEAN AND DRY. Transfer the sample to another bottle for storage. A suitable bottle for storing the sample is one known as a "Boston Round." The closure should be a screw cap with Teflon® or aluminum foil liner.

If new bottles are used, first rinse them thoroughly with acetone or methanol and then dry in a hot-air oven. Hold the bottles in a

desiccator while cooling to ambient temperature.

Protect them from dirt or moisture by enclosure in a polyethylene bag. Rinse used bottles thoroughly with water, detergents, and solvents. Treat the rinsed containers as new bottles.

The sampling device should be bonded to the tank manway (e.g., by resting the chain on the lip of the manway) prior to sampling.

#### **REFERENCED DOCUMENTS RELATED TO SAMPLING:**

ASTM E 300 Practice for Sampling Industrial Chemicals

API RP-500A Classification of Locations for Electrical Installations in Petroleum Refineries

OSHA Regulations, 29 CFR paragraphs 1910.1000 and 1910.2000

U.S. DOT Regulations, 49 CFR Transportation, Subchapters B and C, Parts 171-179

#### **STATIC ELECTRICITY AND GROUNDING**

Chevron Phillips Chemical Company's IAO 16 and IAO 18 are characterized by high electrical resistivity (low conductivity) which can result in the buildup of excess static charge during transfer operations. These materials are classified as low vapor pressure products under the API RP 2003 Guidelines (i.e., a product with a flash point above 100 °F). If these products are handled at temperatures well below their flash point, flammable vapors will not develop. However, a condition for ignition may exist, if IAO 16 and/or IAO 18 are handled at a temperature above their flash point or are contaminated with intermediate or high vapor pressure products. Likewise, in transporting these products, a condition for ignition can exist when the previous load contained a flammable vapor which was not flushed from the storage tank. This type of loading is commonly called "switch loading".

Key operations which have the potential of generating a flammable atmosphere and/or static charge include tank and container filling, splash filling, tank cleaning, sampling, gauging, switch loading, filtering, mixing/agitation, and vacuum truck operations. To minimize the hazard of static electricity during these operations, bonding and grounding may be necessary but may not, by themselves, be sufficient. For more information, refer to OSHA Standard 29 CFR 1910.106, "Flammable and Combustible Liquids", National Fire Protection Association (NFPA) 77, "Recommended Practice on Static Electricity" and/or the American Petroleum Institute (API) Recommended Practice 2003, "Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents."

#### **PRODUCT LOADING/UNLOADING REQUIREMENTS**

Loading operations must be performed only by qualified persons. These individuals must be properly instructed in the loading of IAO 16 and IAO 18. Workers should refer to their site's fire and safety guidelines for personal protective equipment. Though considered noncombustible by most agencies, use caution to avoid creating any sparks which could ignite these products. As the products are being loaded/unloaded, static build up can occur. Therefore, a ground cable must be placed on the container to prevent the build up of static electricity. Use only clean, oil- and dirt-free, spark resistant tools and implements.

The importance of a thorough pre-trip/post-trip inspection can not be over emphasized. The physical inspection process of the container is one of the best methods of minimizing human error, the principle cause of transportation incidents.

Take extreme care to prevent spills. In case material is spilled, wash contaminated areas thoroughly with large quantities of water and collect the liquid in the plant chemical waste system. Drums and trucks can be used for temporary storage until product can be recycled or disposed of properly. See Section 5 for further information.

### **WHEN LOADING OR UNLOADING A VESSEL OR BARGE:**

The United States Coast Guard classifies IAO 16 and IAO 18 as regulated commodities (combustible Grade E cargo under 46 CFR 30.10-15). Vessel/barge owners must comply with 46 CFR Part 30 (Table 30.25-1; cargo name Olefins (C13+, all isomers)).

Plan and control the loading and unloading of IAO 16 and/or IAO 18 to limit personnel exposure and environmental releases. OSHA and the U.S. Coast Guard have published regulations applicable to people involved in the handling of chemical materials. Some of the key elements are:

1. Employee Training
2. Personal Protective Equipment
3. Warning Signs

Clean stainless steel, rust-free mild steel tanks or suitably washed steel tanks are acceptable for transport of this material. Chevron Phillips Chemical Company carefully selects barges to ensure that product quality is not negatively affected during transport. Qualified contractors should be used to inspect, clean, and repair barges in which IAO 16 and IAO 18 are shipped. The contractor should have facilities to dispose of residual product in an acceptable manner.

### **WHEN LOADING OR UNLOADING TANK CARS:**

General purpose tank cars in the Chevron Phillips Chemical Company fleet are DOT 111A100W1 and are stenciled accordingly. They are insulated with exterior heating coils and equipped with both top and bottom loading/unloading valves.

#### **Loading**

Set the brakes, chock wheels, turn on warning lights, erect track warning signs, and connect ground cable. Inspect tank car exterior for any damage or flags and verify that all appliances and test dates are in compliance. Loosen dome cover bolts slightly and leave two (2) bolts hand tight. Check tank car for pressure. Open dome carefully and inspect car interior

for cleanliness and liquid heel. If a liquid heel exists, removal and cleaning may be required depending upon the previous load. Check dome cover bolts, gaskets, and seating surfaces for a secure condition. Flush load filter and spout, if necessary. Remove bottom cap, open outlet valve, and drain, if necessary. Any material from a previous load should be recycled or disposed of in accordance with federal, state, and local regulations. Close bottom outlet valve and leave bottom cap off. If car is equipped with internal steam coils, remove caps. Open product line to tank car and start pump. Frequently check bottom unload valve for any signs of leakage during loading. If leakage occurs, cease loading. Check steam coils for leakage. Load tank car to proper outage or weight desired.

After loading is completed, shut down pump, close block valves for product, and purge line with nitrogen to clear spout. Remove spout, close and tighten dome (with a wrench), and seal all top appliances/covers. Check to ensure that all plugs and fittings are tight. Secure loading ramp and spout, and remove ground cable. Replace bottom cap and tighten with a wrench. Seal bottom unload valve. Secure heater caps if internally coiled car. Remove ground cable, wheel chocks, and warning signs. Turn off track warning light.

#### **Unloading**

Set the brakes, chock wheels, turn on warning lights, erect track warning signs, and connect ground cable. Relieve tank pressure gradually by opening vent valve and loosening dome (manhole cover) at short intervals. Leave dome cover open so air can enter tank while unloading. Operate bottom valve rod handle to see that outlet valve in bottom of tank is seated before removing bottom cap. Loosen bottom cap and allow sufficient time to permit liquid in outlet chamber to escape. Check for leakage from bottom cap. If leakage is absent, remove bottom cap and connect unloading hose (check gasket in hose). Open bottom valve and start unloading pump (it may be necessary to bleed vapors off pump).

After the tank car is unloaded completely, close all unloading valves tightly and remove unloading hose. Tighten all closures except heater coil inlet and outlet pipes which must be left open for drainage. Close dome cover (check gasket), plug or cap all openings and

tighten with wrench. Check gasket, replace bottom cap, and tighten with a wrench. Remove chocks, ground cable, and caution signs. Turn off track warning lights.

**WHEN LOADING OR UNLOADING TANK TRUCKS:**

Open dome tank trucks are normally of the MC/DOT 307 or 407 type and are used to transport hazardous materials.

**Loading**

Check wheel chocks in front and back of truck's rear wheels allowing  $\frac{3}{4}$ " clearance for ease of removal. Connect ground cable. Close bottom valve leaving the cap off to monitor for leakage while loading. Open dome cover and inspect interior for cleanliness. Flush loading spout and filter, if necessary. Visually inspect trailer exterior for damage and inspection dates.

Open product line and start pump. Check bottom unload valve for leakage. Shut down pump, close product block valves, and nitrogen purge line to clear spout. Remove spout, secure dome lid, and seal dome cover. Check all top openings or valves for tightness. Raise loading ramp and secure spout. Replace bottom unload cap and ensure internal/external valves are in closed position. Seal bottom cap. Remove chocks and ground cables.

**Unloading**

Check wheel chocks in front and back of truck's rear wheels allowing  $\frac{3}{4}$ " clearance. Connect ground cable. Relieve all tank pressure by opening a vent valve or slowly loosening dome cover bolts. Remove dome cover or outlet cap so air can enter the tank during unloading. Check internal and external valves ensuring they are closed and remove unloading valve cap slowly to relieve any pressure. Check gasket in loading hose and connect to unloading valve. Open internal and external valves, and start unloading pump.

After product transfer is completed, shut off unloading pump, close internal and external valves, and remove unloading hose checking for possible product in the line. Close, tighten and cap all fittings. Remove chocks and ground cables.

**SAFETY REFERENCES**

The following publications are excellent references for product handling, safety and fire control:

**NFPA No. 10-**  
Portable Fire Extinguisher

**NFPA NO. 11-**  
Foam Extinguishing Systems

**NFPA NO. 70 -**  
National Electrical Code as adopted by  
National Fire Protection Association.

**NFPA NO. 77 -**  
Recommended Practice of Static Electricity as  
adopted by National Fire Protection  
Association.

## PART 3

### **STORAGE DESIGN RECOMMENDATIONS**

#### **STORAGE TANKS**

Storage tanks should be of welded steel construction. Underground storage tanks are not recommended because of the difficulty of locating leaks. However, some states require underground storage tanks. Diking, drainage, and tank supports should be designed to conform with local regulations. A rule of thumb commonly used for determining the size of storage facilities suggests that storage facilities be 1½ times the size of shipments received. The secondary containment requirements as well as tank layout and spacing requirements should be in accordance with NFPA 30. Rotating equipment such as pumps should be kept outside of the secondary containment area. Some facilities may require larger inventories, and thus storage facilities, because of seasonal transportation problems.

The storage tank inlet should be located at the bottom of the tank. Should a top inlet be desired, the fill pipe should be extended to a depth no greater than the diameter of the fill pipe from the bottom of the tank in order to minimize static charge accumulating during filling. The fill pipe should be connected electrically to both the tank flange and the transfer pipeline. The purpose of this electrical connection is to dissipate any static charge which may build up during filling.

Chevron Phillips Chemical Company IAO 16 has a pour point of <14°F and IAO 18 has a pour point of <32°F. Whether or not heating is required depends on the ambient temperature, the duration of that low temperature, and the size of the tank. If the ambient temperature is likely to drop below the product's pour point and the nature of the process allows this product to sit in the lines for a period of time, the tank and lines should be insulated and steam-traced. Uninsulated storage tanks for IAO 16 and IAO 18 may be coated with black paint to keep the product warmer in the winter months.

All of the lines and valves, as well as the tank, can be carbon steel. However, carbon steel lines will accumulate rust if allowed to remain

empty for long periods. In this situation the first few gallons of product moved down the line may have a yellow to orange color and particulates depending on the amount of rust that has accumulated.

Unlined carbon steel tanks may also accumulate rust above the liquid level. This rust, along with the condensate, will settle to the bottom of the tank and may not show up until the tank is stripped. Rust can be avoided by having storage tanks lined with a zinc, epoxy, or other coating that is compatible with these products.

Exercise care in selecting the gasket and seal materials to be used. This product can cause rubber to swell and subsequently deteriorate. Additionally, plastic materials will become brittle and crack or break. Viton® has proven to be compatible with this product.

**Specific bulk storage designs must conform to insurance underwriter's codes and local fire and building regulations. Critical design, placement, installation, and maintenance requirements are usually addressed in these codes and regulations and must be followed.**

Inspect tanks periodically for leaks and service in accordance with API Standard 653.

**Workers should never be permitted to enter an empty tank which has been used for IAO 16 and IAO 18 until the requirements of the OSHA confined space standard (29 CFR 1910.146) and the safe entry recommendation of API Standard 2015 have been met, including, but not limited to, required concentrations for oxygen.**

#### **API AND ANSI DESIGN REFERENCES**

American Petroleum Institute  
1220 L Street, N. W.  
Washington, DC 20005

### **Part I – Design:**

API RP-520: *Sizing, Selection, and Installation of Pressure Relieving Devices in Refineries*

### **Part II – Installation:**

API 601: *Metallic Gaskets for Raised-Face Pipe Flanges and Flanged Connections (Double-Jacketed Corrugated and Spiral-Wound)*

API 620: *Recommended Rules for the Design and Construction of Large Welded, Low-Pressure Storage Tanks*

API 650: *Welded Steel Tanks for Oil Storage*

API Standard 653: *Tank Inspection, Repair, Alteration, and Reconstruction*

API RP-2000: *Venting Atmospheric and Low-Pressure Storage Tanks*

API RP-2003: *Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents*

API Standard 2015: *Safe Entry and Cleaning of Petroleum Storage Tanks*

API RP-2028: *Flame Arresters in Piping System*

API RP-2210: *Flame Arresters for Vents of Tanks Storing Petroleum Products*

API RP-2350: *Overfill Protection for Petroleum Storage Tanks*

American National Standards Institute  
11 West 42nd Street  
New York, New York 10036

ANSI B16.21: *Nonmetallic Flat Gasket for Pipe Flanges*

ANSI B31: *American National Code of Pressure Piping*

## **PARTICULATE MATTER**

Chevron Phillips Chemical Company IAO 16 and IAO 18 should be free of particulate matter when shipped. However, some

particulate matter may originate from outside contamination via the receiving-transfer system.

Particulate matter may be avoided by:

1. Paying careful attention to cleanliness.
2. Filtering product to remove particulate matter before use.

## **FILTERS**

Since small amounts of foreign matter may enter storage tanks and transport vessels from various sources, a filter in the transfer piping between the storage tank and processing equipment is recommended. This can be accomplished by inserting a corrugated cellulose filter paper (5 µm) inside a woven polyester fiber (10 µm mesh) cartridge-type filter. Other types of product compatible filters might also be used. Flow rates and pressures should be used to determine the proper filter for specific situations. Contact Chevron Phillips Chemical Company's Technical Service Group at (800) 852-5531 for specific recommendations.

## **HOSES**

Hard piping is preferred to the use of hoses where possible and practical. If hoses are needed for loading or unloading operations, they should be inspected and pressure tested at the intervals required by the various regulations. A satisfactory type hose is SW-309 PETRO-VAC 150 Tank Truck Hose (seamless nitrile tube with multiple plies of polyester with helix wire and a one piece nitrile blend cover) or a SP-483 modified X-link chemical hose (seamless X-link polyethylene tube with multiple plies of polyester which is supported by a PVC rod helix and a 1 piece blue synthetic cover). Viton® and Teflon® are also recommended. U.S. Coast Guard regulation 33 CFR Part 154.500 applies to hoses used for bulk transfers to and from tank vessels.

## **PUMPS**

Liquid product can be transferred by pump or vacuum. For most product handling, centrifugal pumps with mechanical seals perform



satisfactorily. The pump manufacturer can recommend the proper type of pump if the following parameters are known: 1) flow in gallons per minute, 2) the size and length of suction and discharge lines, 3) the suction and discharge pressures, and 4) the range of product temperatures during transfer. A drain valve should be installed at the lowest point in the system so that the pump and all piping can be completely drained and washed before any maintenance work is done. Totally enclosed fan cooled (TEFC) motors are recommended. However, local fire and insurance codes should be consulted to determine if an explosion-proof motor must be used. Pump seals must be capable of meeting EPA emission standards - this requires tandem or double seals. Tandem seals enhance safety when pumping these products (at elevated temperatures). Demisting systems should be used to keep pump bearings lubed.

The following practices are recommended to minimize the possibility of pump leakage:

1. Mechanical seals in conformance with API 682, 1st edition.
2. Pumps in conformance with API 610, 8th edition are recommended.
3. The pump should be designed so that pump bearings will be able to carry thrust at no flow. Consider selecting non-metallic (PEEK) wear rings to minimize damage if the pump runs dry.
4. The pump shaft should be highly polished.
5. Pumps should not be subjected to forces beyond specified pump tolerances.
6. Vibration monitoring with automatic pump shutdown may be applicable in certain situations.

## **VALVES**

Full-bore ball valves are preferred for pigged pipelines. Gate valves, butterfly valves, or ball valves may be used for pipelines that are not pigged. These valves should be made of cast iron, case steel, or other recommended

materials. Valves should be packed with the following graphite materials:

- Garlock® EVSP Simplified (#9000/98)<sup>(1)</sup>
- Garlock® 70# / 98 (-400 to 1200 °F; 10,000 psi)<sup>(2)</sup>
- Garlock® 1303 (good for steam)<sup>(2)</sup>
- Slade® 3300G (-400 to 1200 °F; 10,000 psi)<sup>(2)</sup>

<sup>(1)</sup>Most efficient packing is the flexible die-form rings with flexible braided end-rings.

<sup>(2)</sup>Used for field repacking.

## **PIPELINES**

The following are recommended practices in engineering pipelines for IAO 16 and IAO 18:

1. A minimum of flanged connections should be used to avoid potential leaks.
2. Lines should not be buried because of the difficulty of checking for leakage.
3. All lines should be sloped with drain valves at appropriate locations so that they can be completely drained for maintenance.
4. All newly installed pipelines should be pressure-tested by an approved method before use.
5. Bellow valves for 2 inch and smaller lines are recommended to eliminate emissions from packing glands.

## **PART 4**

### **HEALTH, ENVIRONMENT, FIRE, AND ACCIDENTAL RELEASE INFORMATION**

Safety Data Sheets (SDS) for NAO products are available from Chevron Phillips Chemical Company to help customers satisfy safe handling and disposal needs and OSHA Hazard Communication Standard requirements. Such information should be requested and studied prior to working with these products. The most current SDS's can be obtained from Chevron Phillips Chemical Company at [www.cpchem.com](http://www.cpchem.com) or by calling (800) 852-5530. Specific questions about SDS's can be sent to [msds@cpchem.com](mailto:msds@cpchem.com).

## **PART 5**

### **TRANSPORTATION INFORMATION AND REGULATORY PROFILES**

Safety Data Sheets (SDS) for NAO products are available from Chevron Phillips Chemical Company to help customers satisfy safe handling and disposal needs and OSHA Hazard Communication Standard requirements. Such information should be requested and studied prior to working with these products. The most current SDS's can be obtained from Chevron Phillips Chemical Company at [www.cpchem.com](http://www.cpchem.com) or by calling (800) 852-5530. Specific questions about SDS's can be sent to [msds@cpchem.com](mailto:msds@cpchem.com).

### **REVISION STATEMENTS**

This revision updates the following sections:

December 2013

1. Operational Excellence statement updated
2. Part 1- Sales Specs removed and replaced with the website information
3. Part 4 – Removed and replaced with SDS reference statement
4. Part 5 – Regulatory Profile removed and replaced with SDS reference statement

Replaces Isomerized 1-Hexadecene and 1-Octadecene 2008 Rev 0.doc

## PART 6

### APPENDIX

#### GLOSSARY OF TERMS, ABBREVIATIONS AND ORGANIZATIONS

ANSI	American National Standards Institute
API	American Petroleum Institute
ASTM	American Society for Testing and Materials
Bonding	The connection of two or more conductive objects by means of a conductor (most commonly a wire or metal plate).
CEIC	Chevron Emergency Information Center
CFR	Code of Federal Regulations
CHEMTREC	Chemical Transportation Emergency Center
Confined Space	An area that by design has limited openings for entry and exit. A confined space has unfavorable natural ventilation and is not intended for continuous worker occupancy.
DOT	Department of Transportation
EPA	Environmental Protection Agency
FDA	Food & Drug Administration
Flash Point	The minimum temperature at which a liquid gives off vapor in sufficient concentrations to form an ignitable mixture with air near the surface of a liquid.
MSDS	Material Safety Data Sheet
NFPA	National Fire Protection Association
NIOSH	National Institute for Occupational Safety and Health
OSHA	Occupational Safety and Health Administration
Peroxides	Compounds containing the -O-O linkage. They occur as impurities in many organic compounds, where they have been slowly formed by the action of oxygen.
SDS	Material Safety Data Sheet
Vapor Pressure	The pressure exerted by a volatile liquid while under defined equilibrium conditions. A common way to measure vapor pressure is in millimeters of mercury (mm Hg).